



T&S BRASS AND BRONZE WORKS, INC.

2 Saddleback Cove / P.O. Box 1088
Travelers Rest, SC 29690

Model No.

016647-45

Item No.

Travelers Rest, SC: 800-476-4103 • Simi Valley, CA: 800-423-0150 • Fax: 864-834-3518 • www.tsbrass.com

This Space for Architect/Engineer Approval


Job Name _____ Date _____

Model Specified _____ Quantity _____

Customer/Wholesaler _____

Contractor _____

Architect/Engineer _____



Water Resistant Faucet
Sensor Cable Connection
(Remove Rubber Cap
to Connect Cable)

Battery Storage
Compartment Access
Cover

1/2" NPSM
Male Outlet

1 1/16"
[27mm]

Removable
Strainer

Mixed Water Elbow
Fitting with
Integral Strainer

1/2" NPSM Female 360°
Swivel Coupling Nut

2"
[51mm]

3 5/8" x 4 3/16" x 2 1/4" Deep
[92mm x 106mm x 57mm]
Control Module Box (Gray),
AC or DC Operated w/ (4)
AA Batteries. Hardwire
Capable using Terminals on Back
(EC-HARDWIRE Required & Sold
Separately)

2"
[51mm]

Water Resistant Transformer Cable
Connection Port (Remove Rubber Plug
to Connect Cable)

3 7/16"
[88mm]

ON/OFF Button



Product Specifications:

ChekPoint Sensor Faucet Control Module with Internal Flow Control
Setting Switches (Gray Module Housing)

Product Compliance:

UL 1951
NSF 61 - Section 9
NSF 372 (Low Lead Content)



T&S BRASS AND BRONZE WORKS, INC.


2 Saddleback Cove / P.O. Box 1088
Travelers Rest, SC 29690

Model No.

016647-45

Item No.

Travelers Rest, SC: 800-476-4103 • Simi Valley, CA: 800-423-0150 • Fax: 864-834-3518 • www.tsbrass.com



Remove (4) Screws and Back Cover to Access Switches.

*Available Water Flow Control Selections:

- Auto Time Out: 15 sec, 30 sec, 45 sec, 60 sec, 3 min, 20 min
- Shut Off Delay: 1 sec, 10 sec, 15 sec, 30 sec
- Auto Flush (30 Seconds After Every 12 Inactive Hours): ON or OFF

Product Specifications:

ChekPoint Sensor Faucet Control Module with Internal Flow Control Setting Switches (Gray Module Housing)

Product Compliance:

UL 1951
NSF 61 - Section 9
NSF 372 (Low Lead Content)